



August, 9th 2016

Simone Furiato
Ebrille Srl
S S Canelli 53/a
Nizza Monferrato, At 14049
Italy

Our Reference: File SV29774 Project 4787507220

Subject: **Test EBRILLE's fittings branded as "Ebrilsmart sizes 1/4", 3/8", 1/2" and 5/8"**

Dear Simone Furiato,

We hereby declare that EBRILLE's fittings branded as "Ebrilsmart", available in sizes 1/4", 3/8", 1/2" and 5/8" were tested according to the requirements in Standard UL 109. See the paragraphs at the bottom of this letter for further information.

All the above sizes complied with the requirements for:

- ❖ **Vibration Test**
- ❖ **Pull Test**
- ❖ **10-day moist ammonia-air stress cracking test**

UL LLC did not select the samples, determine whether the samples were representative of production samples or witness the production of the test samples, nor were we provided with information relative to the formulation or identification of component materials used in the test samples. The test results apply only to the actual samples tested.

The issuance of the report in no way implies Listing, Classification or Recognition by UL LLC and does not authorize the use of UL Listing, Classification or Recognition Marks or any other reference to UL LLC on the product or systems. UL LLC authorizes the above named company to reproduce the Report provided it is reproduced in its entirety. The name, Brand or Marks of UL LLC cannot be used in any packaging, advertising, promotion or marketing relating to the data in the Report, without UL's prior written permission.

UL, its employees and agents shall not be responsible to anyone for the use or nonuse of the information contained in the Report, and shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use of, or inability to use, the information contained in the Report

Very truly yours,

John Silsdorf
Staff Engineering Associate
3014CNBK
Tel: 847-664-3133
john.a.silsdorf@us.ul.com